

LED driver DIP switch selectable fixed output

Product description

- Independent LED driver with cable clamps
- For luminaires of protection class I and protection class II
- Temperature protection
- Constant current LED driver
- Selectable fixed output current via DIP switch 150, 200, 250 and 300 mA
- Max. output power 12 W
- Nominal lifetime up to 50,000 h
- 5 years guarantee

Housing properties

- · Casing: polycarbonat, white
- Type of protection IP20

Functions


- Overload protection
- · Short-circuit protection
- No-load protection

Typical applications

- For spot light and downlight in retail and hospitality application
- For panel light in office application


Standards, page 2

Wiring diagrams and installation examples, page 3























LED driver DIP switch selectable fixed output

IP20 SELV (C & ROHS)

Current setting



Set the current by DIP switch after mains off. Use of DIP switch only after mains off.

150 mA: Switch 1 = Off, Switch 2 = Off

250 mA: Switch 1 = Off, Switch 2 = On





200 mA: Switch 1 = On, Switch 2 = Off

300 mA: Switch 1 = On, Switch 2 = On





Specific technical data

opodinio todininodi didita										
Туре	Output	- Min.	Max.	Max.	Typ. power consumption	Typ. current consumption	,	Max. casing	Ambient	lout select
	current	forward	forward	output	(at 230 V, 50 Hz, full	(at 230 V, 50 Hz, full	(at 230 V, 50 Hz,	temperature	temperature ta	
		voltage	voltage	power	load)	load)	full load)	tc ⁴	max.4	
	150 mA	25 V	40 V	6.3 W	8 W	34 mA	79.0 %	80 °C	-20 +60 °C	1=off / 2=off
LC012/42/150-300Ad	200 mA	25 V	40 V	8.4 W	10 W	42 mA	82.0 %	85 °C	-20 +60 °C	1=on / 2=off
	250 mA	25 V	40 V	10.4 W	11 W	51 mA	84.0 %	85 °C	-20 +60 °C	1=off / 2=on
	300 mA	25 V	40 V	12.7 W	13 W	60 mA	85.5 %	90 °C	-20 +60 °C	1=on / 2=on

¹ Test result at 250 mA.

1. Standards

EN 55015 EN 61000-3-2 EN 61000-3-3 EN 61347-1 EN 61347-2-13 EN 61547 EN 62384

2. Thermal details and lifetime

2.1 Expected lifetime

Expected lifetime for independent use

<u>'</u>					
Туре	Output current	ta	25°C	30°C	40°C
	150 m A	tc	50°C	55°C	65°C
	150 mA	Lifetime	>50,000 h	>50,000 h	50,000 h
	200 m A	tc	50°C	55°C	65°C
LC012/42/150-300Ad	200 mA	Lifetime	>50,000 h	>50,000 h	50,000 h
EC012/42/130-300Ad	250 mA	tc	55°C	60°C	70°C
	250 MA	Lifetime	>50,000 h	>50,000 h	>50,000 h
	200 m A	tc	55°C	60°C	70°C
	300 mA	Lifetime	>50,000 h	>50,000 h	50,000 h

The LED drivers are designed for a lifetime stated above under reference conditions and with a failure probability of less than 10 %.

The relation of tc to ta temperature depends also on the luminaire design. If the measured tc temperature is approx. 5 K below tc max., ta temperature should be checked and eventually critical components (e.g. ELCAP) measured.

² Output current is mean value.


³ Test result at 25 °C.



LED driver DIP switch selectable fixed output

3. Installation / wiring


3.1 Circuit diagram



3.2 Wiring type and cross section for input

For wiring use stranded wire with ferrules or solid wire from $0.5-1.5\ mm$.

Strip 8.5–9.5 mm of insulation from the cables to ensure perfect operation of the push-wire terminals. Use one wire for each terminal connector only.




3.3 Release of the wiring


Press down the "push button" and remove the cable from front.



3.4 Fixing conditions when using as independent Driver with Clip-On

Dry, acidfree, oilfree, fatfree. It is not allowed to exceed the maximum ambient temperature (ta) stated on the device. Minimum distances stated below are recommendations and depend on the actual luminaire. Is not suitable for fixing in corner.






3.5 Wiring type and cross section for output

For wiring use stranded wire with ferrules or solid wire from 0.2–1.5 mm².

Strip 8.5–9.5 mm of insulation from the cables to ensure perfect operation of the push-wire terminals. Use one wire for each terminal connector only.



3.6 Wiring guidelines

- All connections must be kept as short as possible to ensure good EMI behaviour.
- Mains leads should be kept apart from LED driver and other leads (ideally 5 – 10 cm distance)
- Max. length of output wires is 2 m.
- To comply with the EMC regulations run the secondary wires (LED module) in parallel.
- Secondary switching is not permitted.
- · Incorrect wiring can demage LED modules.
- To avoid the damage of the Driver, the wiring must be protected against short circuits to earth (sharp edged metal parts, metal cable clips, louver,etc.).

3.7 Replace LED module

- 1. Mains off
- 2. Remove LED module
- 3. Wait for 20 seconds
- 4. Connect LED module again

Hot plug-in or secondary switching of LEDs is not permitted and may cause a very high current to the LEDs.

3.8 Installation instructions

The LED module and all contact points within the wiring must be sufficiently insulated against 3 kV surge voltage. Air and creepage distance must be maintained.

3.9 Mounting of device

Max. torque for fixing: 0.5 Nm/M4



LED driver DIP switch selectable fixed output

4. Functions

4.1 Short-circuit behaviour

In case of a short circuit on the secondary side (LED) the LED driver switches off. After elimination of the short-circuit fault the LED driver will recover automatically.

4.2 No-load operation

The LED driver works in burst working mode to provide a constant output voltage regulation which allows the application to be able to work safely when LED string opens due to a failure.

4.3 Overload protection

If the maximum load is exceeded by a defined internal limit, the LED driver will protect itself and LED may flicker. After elimination of the overload the nominal operation will recover automatically.

4.4 Overtemperature protection

The LED driver is protected against temporary thermal overheating. If the temperature limit is exceeded, the output current will reduce or LED may flicker. It will recover automatically.

5. Miscellaneous

5.1 Disposal of equipment



Return old devices in accordance with the WEEE directive to suitable recycling facilities.

5.2 Insulation and electric strength testing of luminaires

Electronic devices can be damaged by high voltage. This has to be considered during the routine testing of the luminaires in production.

According to IEC 60598-1 Annex Q (informative only!) or ENEC 303-Annex A,each luminaire should be submitted to an insulation test with 500V for 1 second. This test voltage should be connected between the interconnected phase and neutral terminals and the earth terminal. The insulation resistance must be at least 2 $M\Omega$.

As an alternative, IEC 60598-1 Annex Q describes a test of the electrical strength with 1500V (or $1.414 \times 1500V$). To avoid damage to the electronic devices this test must not be conducted.

5.3 Conditions of use and storage

5% up to max. 85%,

Humidity: not condensed

(max. 56 days/year at 85%)

Storage temperature: -40°C up to max. 80°C

The devices have to be within the specified temperature range (ta) before they can be operated.

5.4 Maximum number of switching cycles

All LED driver are tested with 50,000 switching cycles.

Lifetime declarations are informative and represent no warranty claim.

No warranty if device was opened.